

Date 19/09/2017

job no 13

Jisan Developers.
Shirur, Pune.
College road Shirur.

TO

Principal

P.D.V.V.P. C.O.E Ahmednagar.

Sub:- Testing of TMT rod (16mm), Tensile test.

Respected Sir,

I am Harshal T. Pachange
Site incharge of "Shriram market city" Shirur
(Jisan Developer). We want to test TMT
rod (16 mm). we want to giving the 16mm
rod sample for testing in your lab.

Thanking you.

1) 16 mm (rod) (1 meter length). CP Pipe)

Testing charges - 400/-

Tensile test of one bar.

Sd/-
19/9/17

Dr. S. L. Hake

R. No 01708

19/09/2017

your faithfully

Pachange

Harshal T. Pachange

Dr. V. Patil
PRINCIPAL

Dr. Vitthalrao Vikhe Patil
College of Engineering
Ahmednagar



Dr. Vithalrao Vikhe Patil Foundation's
DR. VITHALRAO VIKHE PATIL COLLEGE OF ENGINEERING,
AHMEDNAGAR.

Ref.No. CEA/CED/TESTING/17-18/13

Date: - 25/09/2017

TEST RESULTS ON STEEL BAR

Name of Party & Address: - M/S JIJAU DEVELOPERS, Shriram Market City, Shirur.

Subject: - Tensile Testing of TMT steel bar of 16 mm diameter.

Ref- Your Letter No-Nil- Date:-19/09/2017.

Testing Charges Rs. - 400/-

Paid Vide Receipt No. : - 01708

Date: - 19/09/2017

RESULT

Tension Test on Steel bar

Sr. No.	Dia. of Bar (mm)	Length of Bar (cm)	Wt. of Bar (gms)	Yield Load (kN)	Yield Stress (N/mm ²)	Ultimate Load (kN)	Tensile Strength (N/mm ²)	Final Gauge Length in (mm)	Elongation (%)
01	16.00	100	1560	127.750	635.375	146.600	729.127	96.23	21.03

Tested By

2-idi Patel

Laboratory Incharge
Testing of Materials

Kawadli
25-09-2017
H.O.D.

Dept. of Civil Engg.

Jan
Principal

Dr.V.V.P.C.O.E. Ahmednagar



Dr. Vithalrao Vikhe Patil
PRINCIPAL
Dr. Vithalrao Vikhe Patil
College of Engineering
Ahmednagar

