

Dr. Vithalrao Vikhe Patil Foundation's

DR. VITHALRAO VIKHE PATIL COLLEGE OF ENGINEERING, AHMEDNAGAR.

Ref. No. : CEA/CED / Water Testing / 2021.

Date-07/07/2021.

TEST RESULT ON WATER SAMPLE .

Name of Party & Address :- SUDARSHAN RELIATIES.

Sr.No. 88/2, Nagar – Pune Raod , Kedgaon , Ahmednagar – 414001 .

Subject :- Testing of Water Sample .

Ref. Letter No. :- -----

Date :- 05/07/2021.

Testing Charges Rs. :- 4000/-

Paid Vide Receipt No. :- 8267

Date :- 06/07/2021.

RESULT

Water Testing Result

Sr. No.	Name of Sample	Hardness In mg/lit.	pH	Alkalinity in mg/lit.	Chloride in mg/lit	Organics Solids in mg/lit	Inorganic Solids in mg/lit	Turbidity NTU
1	Bore No. 2 behind Bungalow	661.20	8.3	150	86.49	310	540	Nil


Tested By V.R. Kulkarni
Prof. V.R. Kulkarni

Head of the Department
Kulkarni

Civil Engineering.

Principal
Dr. Vithalrao Vikhe Patil
College of Engineering
Ahmednagar


V. D. Patel
PRINCIPAL
Dr. Vithalrao Vikhe Patil
College of Engineering
Ahmednagar



SUDARSHAN REALITIES

Sr. No. 88/2, Nagar-Pune Road, Kedgaon, Ahmednagar - 414001

www.icity.rocklazz.com | Accounts@rocklazz.com | +91 8956466964



SUDARSHAN
REALITIES

GST NO.: - 27ACPFS3089L1Z9

Date: 06/07/2021

To,

The principal,

Padmashree Dr. Vitthalrao Vikhe Patil,

College of Engineering, Ahmednagar.

Subject: Regarding Testing of water sample for Construction project.

Respected sir,

Thank you for your swift response conversation on 6th July 2021

As our company construction project of **Mini Township** at kedgaon, Opp. To Rangoli Hotel, Ahmednagar.

For this project, we required testing of following water sample.

- Bore no. 1 near 2nd Ramp.
- Bore no. 2 behind Bungalow.

Testing to be done for following:

1. Hardness
2. Turbidity
3. pH
4. Chloride
5. Inorganic
6. Organic



Yours Sincerely,

Er. Abhishek Junagade

Head of Purchas and execution

For Sudarshan Realities.

Dr. Vitthalrao Vikhe Patil
College of Engineering
Ahmednagar



TO, Principal.

Dr. V.V.P. COE

Ahmednagar

Dt - 5/7/2021

Subject :- Testing of water sample.

Respected Sir,

I am Abhishek Jungade from Indarshan Realities, Ahmednagar. Following are test required for our water sample for construction purpose.

- 1) PH Value
- 2) Hardness
- 3) Chloride
- 4) Inorganic Solids
- 5) Organic Solids.
- 6) Turbidity.

Receipt No. 8267

6/7/2021

RS-4000/-

Details of Sample Given.

- 1) I Sample of Bore water near Second Ramp.
- 2) II Sample of Bore behind bungalow.

Received
Abhishek

5/7/2021

Dr. V.V.P.
PRINCIPAL

Dr. Vitthalrao Vikhe Patil
College of Engineering
Ahmednagar

8956466969

Abhishek Jungade.

TO All Section
Please accept sample for
water & different sample.
RS-4000 only



Yours truly
Abhishek Jungade