

DVVP College of Engg - (from 1-Apr-2019)

Vilad Ghat

Ahmednagar

State Name : Maharashtra, Code : 27

Journal Voucher

No. : 542

Dated : 25-Sep-2019

Particulars	Debit	Credit
Repair & Maint. Electrical <i>Dr</i>	5,910.00	
To Sudarshan Electricals (Sr.Cr.)		5,910.00
New Ref 755 5,910.00 <i>Cr</i>		
	₹ 5,910.00	₹ 5,910.00

On Account of :

Celling Fan Rewinding & Maintance Bill
No.755 AMC No.194/77 dt.18.01.2019


Authorised Signatory



~~Padmashri~~ Dr. Vithalrao Vikhe Patil Foundation's
COLLEGE OF ENGINEERING

Vilad Ghat P. O. M.I.D.C., Ahmednagar - 414 111.

STORES DEPARTMENTS

INTIMATION SLIP CUM INSPECTION REPORT

To, The Principal
COE. A. Nagar.

No. : **467**

Supplier - M/s. Sudeshan Electricals, A. Nagar Date: 19/9/2019

Order No.	T. R. No.	Challan No.	Bill No.	Department
<u>194/77</u>			<u>755</u> <u>19/9/19</u>	<u>Electrical - maint</u> <u>(Fan Repairing work)</u>
Date <u>18/1/19</u>	Date	Date	Date	

Sr. No.	Description of Material	Quantity Ordered	Quantity Received
1)	Ciling fan motor sewing work - 180 x 18.	28 Nos	18 Nos
2)	sewing Tata make 6201/6202 30 x 48.	28 Nos	24 + 24
3)	fan mfd capacitor.	28 Nos	15 Nos
4)	ceiling fan motor Repairing work 20 x 15	28 Nos	28 Nos
5)	fan shaft 30 x 28. - 45 x 2	28 Nos	2 Nos

Remarks of the inspecting Authority with regard to correctness / quality / condition. cost of damages, if any whether replacement in necessary / whether excess supply is to be retained or returned should be specified.

Date of Checking

H.O.D.

Remarks of stores Department As per P.O.

Store Keeper

सुदर्शन इलेक्ट्रीकल्स करिता

Date: 24/07/2019

no. 59
Elect. maint. Dept.

प्रति,

भा. प्राचार्य,

डा. वि. वि. पा. अभियांत्रिकी महाविद्यालय, विरगढाट.

विषय - जुने सिलिंग फ्रेम डुइस्कीवरिती तपासणी
अहवाल पावत.

संदर्भ - 1) सिलिंग फ्रेम डुइस्कीबाबत परिपत्रक क्र. 1763

2) तपासणी अहवाल इले. मेन्टेनन्स विभागामार्फत दि. 24/07/19

महोदय,


वरिष्ठ संदर्भित विषयांत अडवत, आपले महाविद्यालयमधील कॉलेज ग्लेच होस्टेल - A, B & C मधील जुने बंद पडलेले/जमलेले सिलिंग फ्रेम डुइस्कीकलेवरिती सोबत तपासणी अहवाल जोडून पावत आहे. तसेच फ्रेम डुइस्कीकलेवरिती तांत्रिक मागणीत परिपत्रक सोबत पावत आहे. तर सदर 28 नं. सिलिंग फ्रेम स्ट्रुचरमार्फत संबंधित एजेन्सीकडून डुइस्की करण्यावरिती इले. मेन्टेनन्स विभागामार्फत तपासणी अहवाल पावत आहे, ही विनंती.


आपले माहितीस्वरूप व पुढील कार्यवाहीस्वरूप सविनयसादर

सोबत - तपासणी अहवाल व
परिपत्रक.

Stone

कार्यवाहीसाठी 4 दिवस
आत


24/7

आपला विश्वासू,

Elect. Engr
[Elect. maint. Dept.]

Dr. Vithalrao Vikhe Patil College of Engineering, Viladghat

Old Ceiling Fan Testing Report for Repairing Work

DT-22/07/2019

Page No. 1

Elect.Maint.Dept.

Ceiling Fan No.	Rewinding	Weak Winding	Bearing	Shaft	2.5 MFD Condensor	Condensor PVC stand	Bearing Cup	Stater/Rotor Failed
1	✓	-	X	✓	✓	✓	✓	✓
2	✓	-	X	✓	X	X	✓	✓
3	✓	-	X	✓	✓	✓	✓	✓
4	✓	-	X	✓	✓	✓	✓	X(R)
5	X	-	X	✓	X	✓	✓	✓
6	X	-	✓	✓	X	✓	✓	✓
7	X	-	✓	✓	✓	✓	✓	✓
8	✓	-	X	✓	✓	✓	✓	✓
9	X	-	X	✓	✓	✓	✓	✓
10	X	-	X	✓	X	✓	✓	✓
11	X	✓(R)	X	✓	✓	✓	✓	✓
12	✓	-	X	✓	✓	✓	✓	✓
13	X	-	✓	✓	✓	✓	✓	✓
14	X	-	X	✓	✓	✓	✓	X(R)
15	X	✓(R)	X	✓	X	✓	✓	✓
16	X	-	X	✓	X	X	✓	✓
17	X	-	X	✓	X	✓	✓	✓
18	X	-	X	✓	X	✓	✓	X(S)
19	✓	-	X	X	X	X	✓	✓
20	X	-	X	✓	✓	✓	✓	✓
21	X	-	X	✓	X	✓	✓	X(S+R)
22	✓	-	X	X	✓	✓	✓	✓
23	X	-	X	✓	X	✓	✓	✓

Note : 1)Repairing/Replacement is necessary : X (Damaged)

2)Repairing/Replacement is not necessary : ✓ (OK)

3)Weak Winding : Starting or Running winding is failed.Rewinding is necessary.


Wireman


Electrical Supervisor


Electrical Engineer

Dr. Vithalrao Vikhe Patil College of Engineering, Viladghat

Old Ceiling Fan Testing Report for Repairing Work

Dt-22/07/2019

Elect.Maint.Dept.

Page No. 2

Ceiling Fan No.	Rewinding	Weak Winding	Bearing	Shaft	2.5 MFD Condensor	Condensor PVC stand	Bearing Cup	Stator/Rotor Failed
24	✓	—	X	✓	X	✓	✓	X (S)
25	✓	—	X	✓	X	✓	✓	✓
26	X	—	X	✓	X	✓	✓	✓
27	X	—	X	✓	X	✓	✓	✓
28	X	—	✓	✓	✓	✓	✓	✓
18 48 2 15								

Note : 1) Repairing/Replacement is necessary : **X (Damaged)**

2) Repairing/Replacement is not necessary: ✓ (OK)

3)Weak Winding : Starting or Running winding is failed.Rewinding is necessary.

Wireman

Electrical Supervisor

Electrical Engineer

Dr. Vithalrao Vikhe Patil Foundation

(Vadgaon Gurha) Vilad Ghat P.O., MIDC, Ahmednagar-414 111

Ph. No. (0241) 2778042/2779895 Fax 2779782

Ref. No. - DVVPFA/PS/AMC-Elect. Maint./2018-19/ 77

Date - 12 / 1 / 2019

To,

M/s. Sudershan Electricals

Shop no. 6, Sidhibag Shopping Centre,
Ahmednagar.

Mob.: 9881523982

**Subj. Annual Maintenance Contract (AMC) of Ceiling Fan/Exhaust Fan/Cooler/Bearing/
MFD Capacitor repairing work**

**Ref: - In continuation of Previous Work Order No. DVVPFA/PA/COE-AMC-Elect. maint./
2017-18/01/417 dt. 06/04/2017**

R/Sir,

This has reference to our enquiry & your quotation for Annual Maintenance Contract of
Celling Fan/Exhaust Fan/Cooler/Bearing/MFD Capacitor repairing work

We are pleased to finalize as Annual Maintenance Contract with you subject to
terms and conditions as stated below.

1. Rate:

Sr. No.	Particular	Unit	Rate	
			Rs.	Ps.
01	Ceiling Fan motor rewinding work	01	180.00	
02	Exhaust Fan Rewinding work Small	01	250.00	
		01	400.00	
03	Cooler Motor rewinding work Small	01	300.00	
		01	450.00	
04	2.5 MFD Capacitor with clamp	01	20.00	
05	Bearing TATA Make 6201/6202	01	60.00	
06	Ceiling Fan Motor repairing work	01	30.00	
07	4 MFD Capacitor	01	35.00	
08	New Fan Shaft	01	45.00	
09	Brazing/Welding of Bearing Cup	01	50.00	

2. F.O.R. : College site.

3. Taxes : ---

4. Payment: After satisfactory Work Completion & trial.

5. **Annual Maintenance Contract Period: 1st Jan. 2019 to 31st Dec. 2019**

Please return the duplicate copy of Work Rate Contract duly signed by you in token of your
acceptance of the Rate contract.


Your's faithfully,



Secretary

Dr. Vithalrao Vikhe Patil Foundation
Ahmednagar

Copy:

1. The Principal, College of Engineering, Vilad Ghat, A'nagar.
2. The Principal, College of Pharmacy, Vilad Ghat, A'nagar.
3. The Director, IBMRD, Vilad Ghat, A'nagar.
4. The Principal, Industrial Training Institute, MIDC, A'nagar.
5. The Principal, College of Agriculture, Vilad Ghat, A'nagar.
6. The Principal, Junior College, Vilad Ghat, A'nagar.
7. Elect. maint. dept.
8. Account Section (fdn.)




21/1

