

DVVP College of Engg - (from 1-Apr-2019)

Vilad Ghat

Ahmednagar

State Name : Maharashtra, Code : 27

Journal Voucher

No. : 543

Dated : 25-Sep-2019

Particulars	Debit	Credit
Repair & Maint. Electrical Dr	5,710.00	
To Sudarshan Electricals (Sr.Cr.)		5,710.00
New Ref 756 5,710.00 Cr		
	₹ 5,710.00	₹ 5,710.00

On Account of :

Celling Fan Rewinding & Maintance Bill
No.756 AMC No.194/77 dt.18.01.2019

Authorized Signatory

~~Padmashri~~ Dr. Vithalrao Vikhe Patil Foundation's

COLLEGE OF ENGINEERING

Vilad Ghat P. O. M.I.D.C., Ahmednagar - 414 111.

STORES DEPARTMENTS

INTIMATION SLIP CUM INSPECTION REPORT

To, The principal

No. : **466**

COE. A. Nagar

Supplier - M/s. Sudeshan Electricals, A. Nagar

Date : 29/6/2019

Order No.	T. R. No.	Challan No.	Bill No.	Department
<u>194/27</u> Date <u>18/1/19</u>			<u>256</u> Date <u>29/6/19</u>	<u>Electrical</u> <u>maint</u> <u>(fan repairing work)</u>

Sr. No.	Description of Material	Quantity Ordered	Quantity Received
1)	ceiling fan motor rewinding work - <u>180x18</u>	24 Nos	18 Nos
2)	6202 + 6201 22511 <u>21 + 21 * 42</u> - <u>30x42</u>	24 Nos	21 + 21
3)	<u>405</u> 4 fan mtd condensor <u>20x20</u> -	24 Nos	20 Nos
4)	ceiling fan motor rewinding work - <u>23x23</u>	24 Nos	24 Nos
5)	2 fan shaft - <u>45x2</u>	24 Nos	2 Nos

Remarks of the inspecting Authority with regard to correctness / quality / condition. cost of damages, if any whether replacement in necessary / whether excess supply is to be retained or returned should be specified.

Date of Checking

[Signature]
H.O.D.

Remarks of stores Department As per P.O.

[Signature]
Store Keeper

सुदर्शन इलेक्ट्रीकल्स करिता

Date: 9/05/2019

no. 20
Elect. maint. Dept.

प्रती,

मा. प्राचार्य,

डॉ. वि. वि. पा. अभियांत्रिकी महाविद्यालय, विरडगाव.

विषय - जुने सिलिंग फॅन दुदस्तीबाबत.

संदर्भ - CEA/meeting/2019/1012/Dtdt-30/04/2019

महोदय,

वरील संदर्भित विषयास अनुसरून, आपले महाविद्यालयातील जुने सिलिंग फॅन दुदस्तीकरिता स्टोअरमार्फत मे. सुदर्शन इलेक्ट्रीकल्स भ. नगर यांचेकडे दिले जाताना सदर फॅन दुदस्तीकरिता कोणता स्पेअरपार्ट बदलणे आवश्यक आहे व उर्वरित स्पेअरपार्ट व्यवस्थित आहे, याबाबतचा अहवाल सोबत जोडून पाठवत आहे. याप्रमाणे जुने सिलिंग फॅन दुदस्ती होणे अपेक्षित आहे. परंतु, सदर जुन्या सिलिंग फॅनची चाचणी (Testing) आपले कॉलेजमधील इलेक्ट्रीशियन/वायरमन यांनी त्यांच्या अनुभवानुसार केलेली आहे. प्रत्यक्ष दुदस्ती करणारी राजेव्सी वायरमन अनिदित्त झाल्याने जुने सिलिंग दुदस्ती करण्यासाठी Testing Report व Repair यांमध्ये सुमारे 25% स्पेअरपार्ट बदलण्याचा फरक पडू शकतो. तरी याबाबत व दुदस्तीकरिता स्टोअर विभागास सूचना हावी, ती विनंती.

आपले माहितीस व पुढील कार्यवाहीसव सविनयसह.
सोबत - Ceiling Fan (Old)

Testing Report

9/5/19

12.10 PM

Stone
R. A.
[Signature]
0105

आपला विश्वासू,

[Signature]
Elect. Engr

[Elect. maint. Dept.]

Dr. Vithalrao Vikhe Patil College of Engineering, Viladghat

Old Ceiling Fan Testing Report for Repairing Work


①

Dt- 8/05/2019

Elect.Maint.Dept.

Ceiling Fan No.	Rewinding	Weak Winding	Bearing	Shaft	2.5 MFD Condensor	Condensor PVC stand	Fan Stator	Fan Rotor
1	X	X	✓	X	✓	✓	X	X
2	-	✓	✓	X	X	X	X	X
3	✓	-	✓	X	✓	X	X	X
4	-	✓	✓	X	✓	X	X	X
5	X	X	✓	✓	✓	X	X	X
6	-	✓	✓	X	✓	X	X	X
7	✓	-	✓	X	X	X	X	X
8	X	X	✓	X	X	X	X	X
9	X	X	✓	X	✓	X	X	X
10	-	✓	✓	X	✓	X	X	X
11	✓	-	X	X	X	X	X	X
12	-	✓	✓	X	✓	X	X	X
13	-	✓	X	X	✓	X	X	X
14	X	X	✓	X	✓	✓	X	X
15	✓	-	✓	X	✓	X	X	X
16	X	X	✓	X	✓	X	X	X
17	X	X	✓	X	✓	X	X	X
18	-	✓	✓	✓	✓	X	X	X
19	X	X	✓	X	✓	X	X	X
20	-	✓	X	X	✓	X	X	X

✓ : Replacement necessary, X : Not Required (OK)


Wireman


Electrical Supervisor


Electrical Engineer

②

Elect.Maint.Dept.

✓: Replacement necessary, X: Not Required (OK)

9/05/2019
Electrical Engineer

Dr. Vithalrao Vikhe Patil Foundation

(Vadgaon Ghat) Vilad Ghat, P.O. MIDC, Ahmednagar-414 111

Ph. No. (0241) 2778042/2779895 Fax 2779782

Ref. No. - DVVPFA/PS/AMC-Elect. Maint./2018-19/ 77

Date - 21/11/2019

To,

M/s. Sudershan Electricals

Shop no. 6, Sidhibag Shopping Centre,

Ahmednagar.

Mob.: 9881523982

Subject: Annual Maintenance Contract (AMC) of Ceiling Fan/Exhaust Fan/Cooler/Bearing/
MFD Capacitor repairing work

Ref: - In continuation of Previous Work Order No. DVVPFA/PA/COE-AMC-Elect. maint./
2017-18/01/417 dt. 06/04/2017

R/Sir,

This has reference to our enquiry & your quotation for Annual Maintenance Contract of
Celling Fan/Exhaust Fan/Cooler/Bearing/MFD Capacitor repairing work

We are pleased to finalize as Annual Maintenance Contract with you subject to
terms and conditions as stated below.

1. Rate:

Sr. No.	Particular	Unit	Rate	
			Rs.	Ps.
01	Ceiling Fan motor rewinding work	01	180.00	
02	Exhaust Fan Rewinding work			
	Small	01	250.00	
	Big	01	400.00	
03	Cooler Motor rewinding work			
	Small	01	300.00	
	Big	01	450.00	
04	2.5 MFD Capacitor with clamp	01	20.00	
05	Bearing TATA Make 6201/6202	01	60.00	
06	Ceiling Fan Motor repairing work	01	30.00	
07	4 MFD Capacitor	01	35.00	
08	New Fan Shaft	01	45.00	
09	Brazing/Welding of Bearing Cup	01	50.00	

2. F.O.R. : College site.

3. Taxes : ---

4. Payment: After satisfactory Work Completion & trial.

5. Annual Maintenance Contract Period: 1st Jan. 2019 to 31st Dec. 2019

Please return the duplicate copy of Work Rate Contract duly signed by you in token of your
acceptance of the Rate contract.

Your's faithfully,

Secretary

Dr. Vithalrao Vikhe Patil Foundation
Ahmednagar

Copy:

1. The Principal, College of Engineering, Vilad Ghat, A'nagar.
2. The Principal, College of Pharmacy, Vilad Ghat, A'nagar.
3. The Director, IBMRD, Vilad Ghat, A'nagar.
4. The Principal, Industrial Training Institute, MIDC, A'nagar.
5. The Principal, College of Agriculture, Vilad Ghat, A'nagar.
6. The Principal, Junior College, Vilad Ghat, A'nagar.
7. Elect. maint. dept.
8. Account Section (fdn.)

COCA

77

21/11/19