

DVVP College of Engg
Vilad Ghat
Ahmednagar
State Name : Maharashtra, Code : 27

Journal Voucher

No. : 804

Dated : 6-Jan-2020

Particulars	Debit	Credit
Repair & Maint. Electrical <i>Dr</i>	7,335.00	
To Sudarshan Electricals (Sr.Cr.)		7,335.00
New Ref 784 7,335.00 <i>Cr</i>		
	₹ 7,335.00	₹ 7,335.00

On Account of :

Celling Fan Rewinding & Maintance Bill
No.784 AMC No.194/77 dt.18.01.2019



Authorised Signatory



~~Padmashri~~ Dr. Vithalrao Vikhe Patil Foundation's

COLLEGE OF ENGINEERING

Vilad Ghat P. O. M.I.D.C., Ahmednagar - 414 111.

STORES DEPARTMENTS

INTIMATION SLIP CUM INSPECTION REPORT

To, The principal,
COE A Nagar.

No. : **492**

Supplier - MR Sudershan Electricals, A Nagar.

Date : 27 / 12 / 2019

Order No.	T. R. No.	Challan No.	Bill No.	Department
<u>194/77</u>			<u>784</u>	<u>Electrical -</u>
Date <u>18/1/19</u>	Date	Date	Date <u>25/12/19</u>	<u>- maint</u>
				<u>(fan Repairing work)</u>

Sr. No.	Description of Material	Quantity Ordered	Quantity Received
1)	Ceiling fan motor rewinding work - 180 x 24	33 Nos	24 Nos
2)	Bearing Tata make 6201 & 6202 - 30 x 60	33 Nos	30 & 30
3)	fan mfd capacitor 20 x 15	33 Nos	15 Nos
4)	Ceiling fan motor Repairing work - 30 x 32	33 Nos	32 Nos
5)	Fan shaft - 45 x 11 (01 for running)	33 Nos	11 Nos

Remarks of the inspecting Authority with regard to correctness / quality / condition. cost of damages, if any whether replacement in necessary / whether excess supply is to be retained or returned should be specified.

Date of Checking

01/01/2020

[Signature]
H.O.D.

Remarks of stores Department

As per p-o.

[Signature]
Store Keeper

सुदर्शन
सुदर्शन इलेक्ट्रीकल्स करिता

Date: 12/11/2019

no. 6

इले. देखभाल विभाग

प्रती,

मा. प्राचार्य,

डॉ. वि. वि. पा. फंडेशन, अभियांत्रिकी महाविद्यालय
विष्णु घाट - अ, नगव.

विषय :- सिचिंग फैन टेस्टिंग रिपोर्ट काबद

मा. महोदय,

कारण वरील विषयास अनुसरु आपणास
महाविद्यालय येथील सस्यस्य इले. कामेसु येथील विभागाने
सिचिंग फैन टेस्टिंग रिपोर्ट सादर झालेला असुन. येथील
विभागाने सुपन्न करव्यास याची व याकड गा ठिकसु ध्याता.
वरील आपणा माहितीसुन व यु धीन कार्याही सती

सादर.

Ceiling Fan Testing Report - 33 nos.

R/SZ,

Pl. Give permission
for repairing of old
Ceiling fan = 33 nos.
(As per Testing Report)

store
in
14/11

8/11
elect Engg
12/11/2019

कार्याचे
आपला विश्वास
[Signature]
(Shri. P. S. M.)
Elec. Maint. Supervisor

सुदर्शन इलेक्ट्रीकल्स करिता

Dr. Vithalrao Vikhe Patil College of Engineering, Viladghat

Old Ceiling Fan Testing Report for Repairing Work

DT-12/11/2019

Elect.Maint.Dept.

Ceiling Fan No.	Rewinding	Weak Winding	Bearing	Shaft	2.5 MFD Condensor	Condensor PVC stand	Bearing Cup	Stator/Rotor Failed
1	✓	—	X	✓	✓	✓	✓	✓
2	X	X	X	✓	✓	✓	✓	✓
3	✓	—	X	X	✓	✓	✓	✓
4	✓	—	X	✓	✓	✓	✓	✓
5	X	X	X	✓	✓	✓	✓	✓
6	✓	—	X	✓	X	✓	✓	✓
7	X	X	X	✓	✓	✓	✓	✓
8	X	X	X	✓	✓	✓	✓	✓
9	X	X	X	✓	✓	✓	✓	✓
10	✓	—	X	X	✓	✓	✓	✓
11	X	X	X	✓	✓	✓	✓	✓
12	X	X	X	X	✓	✓	✓	✓
13	X	X	X	✓	✓	✓	✓	✓
14	✓	—	X	X	✓	✓	✓	✓
15	✓	—	X	X	✓	✓	✓	✓
16	✓	—	X	X	✓	✓	✓	✓
17	✓	—	X	✓	✓	✓	✓	✓
18	✓	—	X	✓	✓	✓	✓	✓
19	✓	—	X	✓	✓	✓	✓	✓
20	✓	—	X	X	✓	✓	✓	✓
21	X	X	X	✓	X	✓	✓	✓
22	✓	—	X	✓	X	✓	✓	✓
23	X	X	X	X	X	X	X	✓

Note : 1)Repairing/Replacement is necessary : X

2)Repairing/Replacement is not necessary : ✓

3)Weak Winding : Starting or Running winding is failed.Rewinding is necessary.

Wireman

Electrical Supervisor

Electrical Engineer
12/11/19

Kokle

Dr. Vithalrao Vikhe Patil College of Engineering, Viladghat

Old Ceiling Fan Testing Report for Repairing Work

DT-12/11/2019

Elect.Maint.Dept.

Ceiling Fan No.	Rewinding	Weak Winding	Bearing	Shaft	2.5 MFD Condensor	Condensor PVC stand	Bearing Cup	Stator/Rotor Failed
24	X	X	X	X	X	✓	✓	✓
25	X	X	X	✓	X	✓	✓	✓
26	X	X	X	✓	X	X	✓	✓
27	✓	—	X	X	X	✓	✓	✓
28	X	X	X	✓	X	X	✓	✓
29	X	X	X	✓	X	✓	✓	✓
30	X	X	X	✓	X	X	✓	✓
31	✓	—	X	✓	✓	✓	✓	✓
32	X	X	X	X	✓	X	✓	✓
33	X	X	X	X	✓	X	✓	✓
(Only 04 Nos. Old ceiling fan, blade fitting nuts are not available.)								

Note : 1) Repairing/Replacement is necessary : ✕

2) Repairing/Replacement is not necessary: ✓

3)Weak Winding : Starting or Running winding is failed.Rewinding is necessary.

Wireman

Electrical Supervisor


28/12/11
Electrical Engineer

Vadgaon Gupta Vilad Ghat, Post- M.I D.C., Ahmednagar 414111

DELIVERY CHALLAN

Date _____

To, Mrs. Sudershan Electricals. Anugol



STORE KEEPER
STORE CLERK
College of Engineering
Ahmednagar

Material as Mentioned above is received in good order.

marks

RECEIVERS SIGNATURE

Ref. No. - DVVPFA/PS/AMC-Elect. Maint./2018-19/ 77
To,

Date: 28 / 1 / 2019

M/s. Sudershan Electricals
Shop no. 6, Sidhibag Shopping Centre,
Ahmednagar.
Mob.: 9881523982

Subj: Annual Maintenance Contract (AMC) of Ceiling Fan/Exhaust Fan/Cooler/Bearing/
MFD Capacitor repairing work

Ref: - In continuation of Previous Work Order No. DVVPFA/PA/COE-AMC-Elect. maint./
2017-18/01/417 dt. 06/04/2017

R/Sir,

This has reference to our enquiry & your quotation for Annual Maintenance Contract of
Celling Fan/Exhaust Fan/Cooler/Bearing/MFD Capacitor repairing work

We are pleased to finalize as Annual Maintenance Contract with you subject to
terms and conditions as stated below.

1. Rate:

Sr. No.	Particular	Unit	Rate	
			Rs.	Ps.
01	Ceiling Fan motor rewinding work	01	180.00	
02	Exhaust Fan Rewinding work Small	01	250.00	
		01	400.00	
03	Cooler Motor rewinding work Small	01	300.00	
		01	450.00	
04	2.5 MFD Capacitor with clamp	01	20.00	
05	Bearing TATA Make 6201/6202	01	60.00	
06	Ceiling Fan Motor repairing work	01	30.00	
07	4 MFD Capacitor	01	35.00	
08	New Fan Shaft	01	45.00	
09	Brazing/Welding of Bearing Cup	01	50.00	

2. F.O.R. : College site.

3. Taxes : ---

4. Payment: After satisfactory Work Completion & trial.

5. **Annual Maintenance Contract Period: 1st Jan. 2019 to 31st Dec. 2019**

Please return the duplicate copy of Work Rate Contract duly signed by you in token of your
acceptance of the Rate contract.

Your's faithfully,

Secretary

Dr. Vithalrao Vikhe Patil Foundation
Ahmednagar

Copy:

1. The Principal, College of Engineering, Vilad Ghat, A'nagar.
2. The Principal, College of Pharmacy, Vilad Ghat, A'nagar.
3. The Director, IBMRD, Vilad Ghat, A'nagar.
4. The Principal, Industrial Training Institute, MIDC, A'nagar.
5. The Principal, College of Agriculture, Vilad Ghat, A'nagar.
6. The Principal, Junior College, Vilad Ghat, A'nagar.
7. Elect. maint. dept.
8. Account Section (fdn.)

77
21/1/19